



RURAL DRINKING WATER & SANITATION DEPARTMENT, GOKAK
Sub Divisional Water Quality Chemical Testing Laboratory Gokak
 Near Basaveshwar Circle, Infront of JSS College Gokak 591307
 rdwsd.wqmspgokak@gmail.com



TEST REPORT

To, School Name: S.D.V.S Sangh's Shri A B Patil Public School Old P.B Road, SDVS Sangh Campus, Sankeshwar Pin-591313 Tal:Hukkeri Dist: Belagavi Contact:7337707951 e-mail:shriabpatilpublicschool@gmail.com				Report date: 01-04-2026	
				Report Number: 020	
				Reference: Sample receipt Form	
				Sample receipt date: 31-03-2026	
				Sample code:020	
				Date of Sample collection: 31-03-2026	
				Analysis start date: 31-03-2026	
				Analysis completion date: 01-04-2026	
				Sample collection protocol: IS 3025(Part-1)	
Sample Particulars: Open well (Filter Water)				Sample quantity: 1litre	
Sl.No	Test	Results	Acceptable Limit IS 10500: 2012 RA:2018	Permissible Limit IS 10500: 2012 RA:2018	Protocol
1.	pH Value @Temp25.0°C	7.92	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance,µS/cm@Temp°C	231	—	—	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) :1983
6.	Turbidity, NTU	0.8	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	111	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	24.0	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	44.03	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	9.78	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	3.91	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	15.43	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	9.25	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.07	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	8.45	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.06	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021					
 Analysed by: Analyst RDWS Sub-divn, Gokak					

Note:

RDWSD/WQMSF/DR/01. Sub-Dn. Gokak

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWS/WQMSF/DR-01

MANAGER
SHRI A. B. PATIL PUBLIC SCHOOL
SANKESHWAR-591313

PRINCIPAL
SHRI A. B. PATIL PUBLIC SCHOOL
SANKESHWAR - 591313





GOVERNMENT OF KARNATAKA

No.TMC/SKV/H.S/2023-24/

Office of the
Town Municipal Council, Sankeshwar,
Dated: 15/04/2025.

TO WHOM SO EVER IT MAY CONCERN

CERTIFICATE

This is to certify that after inspection by the Health Inspector, Health and Sanitary conditions in S.D.V.S. Sangh's Shri A. B. Patil Public School, Sankeshwar situated in R.S.No.22A/2, S.D.V.S. Sangh Campus, Old P.B. Road, Sankeshwar-591313 Dist: Belagavi is found to be good at the time of Inspection. Also checked Drinking Water (RO) of CBSE School, it is to be in good condition.

Self Attested
[Signature]
PRINCIPAL
Shri A.B. Patil Public School,
Sankeshwar-591313

Self Attested
[Signature] 15/4/24
Chief Officer,
T.M.C. SANKESHWAR.
[Signature]
MANAGER
Shri A.B. Patil Public School,
Sankeshwar-591313